

## Test Lamp T-229/4P for UV, IR and UV/IR Flame detectors

• Data Sheet



This document is available in 18 other languages on www.testlamp.com

## **Description:**

The SENSE-WARE T-229/4P flame detector test lamp activates UV, IR and UV/IR flame detectors which detect in the 185-235 nm UV and 4.4  $\mu$  IR frequency ranges. For UV only detectors the maximum distance is up to 8 meters (26 ft) in the continuous mode. The test range for IR and UV/IR detectors is up to 4 meters (13 ft). Most IR Flame detectors have an extra alarm criterion; analyzing the flicker frequency of a fire. In order to simulate the flame flicker, the lamp needs to be pulse operated. For this, the test lamp T-229/4P can be put into the pulse mode by means of a selection switch on the left side of the test lamp. The lamp then emits pulsed light with a frequency of approx. 2 Hz. After the alarm delay time the IR or UV/IR flame detector will activate.

Not suitable for IR/IR- (dual IR), IR/IR/IR (IR3 or triple IR) flame detectors.

Only for use in safe areas.

## **Specifications:**

100-240 Vac, 1600 mA switching with plugs for US, EU, GB and AU
up to 8 m (26 ft) in continue mode, up to 4 m (13 ft) in pulse mode
up to 4 m (13 ft)
sealed Lead Acid battery, 12 Vdc / 2.7 Ah
12 Vdc / 100 W
10-15 minutes under optimal conditions and continuous use
PC/ABS
310 x 220 x 210 mm (12 5/8 x 9 x 8 5/8 " )
2.1 kg (4.62 lbs)
IP30 / NEMA 1
+4 to +40 °C (+39 to +104 °F)
EU, 8531 10 30
Case: polypropylene, inlay polyurethane
440 x 340 x 280 mm (17 3/8 x 13 3/8 x 11 " )
5.0 kg (11.1 lbs)

## **Battery specifications:**

Battery type	sealed rechargeable lead acid battery
Battery voltage and capacity	12 Vdc/ 2.7 Ah
Dimensions	l x w x h 103 x 70 x 46 mm
Туре	BATT4P

Please check the latest version of this data sheet (several languages) on www.testlamp.com.

Due to the policy of continued product development SENSE-WARE Fire and Gas Detection BV reserves the right to alter or amend information in their publications without prior notice and no responsibility can be accepted for errors or omissions.